SAROVAR

M.G. Rajashekhar
Hydro Geologist M.Sc, (Geo), D.E.G., FGS
Ground Water & Rain Water Harvesting Consultant

Yield dept

6½" dia Shallow - Borewell no 1/6
Behind Pothys Station

Yield test carried out and found to be 3 4

359, 13th Cross, 3rd Block, BEL Layout, Vidyaranyapuram, Bangalore-560 097.
Tel : +91-80-23644118 Mobile : 9880099118 Email : mgthimma@gmail.com

Scanned by CamScanner

GROUND WATER SURVEY REPORT

~~OPEN WELL~~ / BOREWELL
DATA OF SURVEY

a) Name of the Party : BBMP under Jb

b) Location of the Site : Behind Kalinga Sweets

c) Area of the land : Gachibowli

INVESTIGATION REPORT

1) GEOLOGY OF THE AREA : Granite gneiss, Charnockite

2) Recommended Site for drilling : W1
3) Total depth to be drilled : 1050-1200'
4) Approx. casing pipe required : 140-160'
5) No. of water bearing Zones : —4—
6) No. of favorable spots marked : —2—
7) Qty. of water expected : 2LPM
8) Method of survey carried out : Geohydrological Survey
9) Remarks : 6½" drilling at W1

400-1250'

Terms & Conditions

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

BOREWELL SITE PLAN



Scanned by CamScanner

SAROVAR

M.G. Rajashekhar
Hydro Geologist M.Sc, (Geo), D.E.G., FGS
Ground Water & Rain Water Harvesting Consultant

Yield test

6½" dia borewell drilled at-
Bhoopasandra, Nallagutahalli Taluk.

Yield test carried out and found
to be 3"

359, 13th Cross, 3rd Block, BEL Layout, Vidyaranyapuram, Bangalore-560 097.
Tel : +91-80-23644118 Mobile : 9880099118 Email : mgthimma@gmail.com

Scanned by CamScanner

GROUND WATER SURVEY REPORT

~~OPEN WELL~~ / BOREWELL
DATA OF SURVEY

a) Name of the Party : B.B.M.P Ward-16

b) Location of the Site : Beside Muthayamma Temple

c) Area of the land :

INVESTIGATION REPORT

1) GEOLOGY OF THE AREA : Granite gneiss

2) Recommended Site for drilling : W1

3) Total depth to be drilled : 1000-1200'

4) Approx. casing pipe required : 145-160'

5) No. of water bearing Zones : - 4 -

6) No. of favorable spots marked : - 1 -

7) Qty. of water expected : 2½-3"

8) Method of survey carried out : Geophysical

9) Remarks : 6½" dia bore well W1

Water Source at 440'-1100'

Terms & Conditions

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

BOREWELL SITE PLAN



#133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore-560056
e-mail: civilqualityconsultants@gmail.com Ph: 080-23240644 Mob: 9886998316

Scanned by CamScanner